

TOWN OF NEWINGTON

BID NO. 4, 2015-16

FIRE DEPARTMENT COMPRESSED BREATHING AIR COMPRESSOR

ADDENDUM NUMBER ONE

May 5, 2015

The following additions, deletions and changes are hereby provided and shall be considered an integral part of the Bid documents. This Addendum consists of one (1) page. Below are the questions that have been received by the Town and the Town's responses to those questions, which are the official responses that supersede any other prior written or oral statements.

1. I would like to confirm Voltage, Breaker size, Wire size and Phase at both locations. Answer: At Company One there is a 60 amp circuit breaker, three phase, 208 volts and number 6 wire. At Company Two there is a 30 amp breaker, three phase, 208 volts and 10 gauge wire.

END OF ADDENDUM NUMBER ONE